

Number of windows: 3


Window opening surface : 6 m² (all windows)

Position of monitoring stations : See map

Position of HVAC: No HVAC

Average number of occupants : 20

Average occupation time (school hours?)



Event Log

Start time	End time	Event	Notes
13:00	13:45	Lesson restart (20 students)	3741 PPM (door closed, windows closed)
13:45	13:55	Break	4389 PPM (1 window opened, students out)
13:55	14:40	Lesson restart	4021 PPM (door closed, windows closed)
14:40	14:50	Break	5048 PPM(1 window opened, students out)
14:50	15:35	Lesson restart	4524 PPM (door closed, windows closed)
15:35	15:45	Break	3657 PPM(1 window opened, students out)
15:45	16:30	Lesson restart	2014PPM (door closed, windows closed)
16:30	16:40	Break	797 PPM(1 window opened, students out)
16:40	17:25	Lesson restart	1116PPM (door closed, windows closed)
17:30		Lesson ends, students out, windows closed	1059 PPM