


Position of HVAC: No HVAC

Average number of occupants : 20

Average occupation time (school hours?)

6h / day



Event Log

Start time	End time	Event	Notes
12:05	12:50	Lesson restart (22 students)	1628 PPM (door closed, windows closed)
12:50	13:00	Break	1745 PPM (1 window opened, students out)
13:00	13:45	Lesson restart	2364 PPM (door closed, windows closed)
13:45	13:55	Break	1203 PPM (1 window opened, students out)
13:55	14:40	Lesson restart	1581 PPM (door closed, windows closed)
14:40	14:50	Break	1792 PPM(1 window opened, students out)
14:50	15:35	Lesson restart	1855 PPM (door closed, windows closed)
15:35	15:45	Break	1183 PPM(1 window opened, students out)
15:45	16:30	Lesson restart	1183PPM (door closed, windows closed)
16:30	16:40	Lesson ends, students out, windows closed	1183 PPM(1 window opened, students out)