

Type of activity: Continous Monitoring

## Info about workspace

School and Class : a IX-a A

Room destination : TEACHING ACTIVITES

Room surface: 100 m<sup>2</sup>

Room volume : 330 m<sup>3</sup>

Number of windows: 3

Window opening surface : 6 m<sup>2</sup> (all windows)


Position of monitoring stations : See map

Position of HVAC: No HVAC

Average number of occupants : 22

Average occupation time (school hours?)

6h / day



## **Event Log**

Start time	End time	Event	Notes
12:05	12:50	Lesson restart (22 students)	1554 PPM (door closed, windows closed)
12:50	13:00	Break	1821 PPM (1 window opened, students in)
13:00	13:45	Lesson restart	1962 PPM (door closed, windows closed)
13:45	13:55	Break	1510 PPM ( 1 window opened, students out)
13:55	14:40	Lesson restart	1933 PPM (door closed, windows closed)
14:40	14:50	Break	2276 PPM (1 window opened, students out)
14:50	15:35	Lesson restart	3366 PPM (door closed, windows closed)
15:35	15:45	Break	3935 PPM( windows closed, students in)
15:45	16:30	Lesson restart	4042 PPM (door closed, windows closed)
16:30		Lesson ends, students out, windows closed	4042 PPM